

Bureau of Buildings
 Department of Development
 515 North Avenue
 New Rochelle, N.Y. 10801

Phone: (914) 654-2035
 Fax: (914) 654-2031



Paul Vacca, C.E.O.
 Deputy Commissioner/Building Official

Peter Warycha, C.E.O.
 Deputy Building Official

**City of New Rochelle
 New York**

L.R.A./L.P.E. FIELD INSPECTION CHECKLIST

<u>INSPECTION TYPE</u>	<u>FIELD CONDITION</u>	<u># INSPECTED</u>	<u># PASSED</u>	<u># FAILED</u>	<u>DATE</u>
PRE-SHEETROCK INSPECTIONS:					
Air Sealing (Around Entire House) (N1102.4.1)	_____	_____	_____	_____	_____
Fenestration Air Leakage (Windows, Sliding Doors, Skylights - .3 cfm/ft ²) (Swinging Door - .5 cfm/ft ²) (N1102.4.2)	_____	_____	_____	_____	_____
Window U Factor (Table N1102.1.2)	_____	_____	_____	_____	_____
Exterior Doors U Factor (Table N1102.1.2)					
Door 1	_____	_____	_____	_____	_____
Door 2	_____	_____	_____	_____	_____
Door 3	_____	_____	_____	_____	_____
Door 4	_____	_____	_____	_____	_____
Additional Doors	_____	_____	_____	_____	_____
AFTER WALLS ARE CLOSED:					
Fenestration Caulking & Sealing (N1102.4.1)	_____	_____	_____	_____	_____
HVAC Duct Sealing (N1103.2.2)	_____	_____	_____	_____	_____
Weatherstripping/Gaskets On Doors (Bottom & Sides) (N1102.4.1)	_____	_____	_____	_____	_____
Panel Certificate (N1101.8)	_____	_____	_____	_____	_____

Registered Architect/Professional Engineer shall submit a spec on the window confirming compliance with N1102.4.2 of the Residential Code Fenestration Air Leakage.

If any alternatives permitted by the Residential Code of New York State have been utilized, describe the alternatives utilized and reference the applied code sections.

Narrative (No. of stories, No. of bedrooms, General description of residence per floor):

CODE SECTIONS ARE REFERENCED FROM RESIDENTIAL CODE OF NYS, 2007 EDITION